

NON-CONFIDENTIAL DESIGN-BUILD QUESTIONS
Carolina Crossroads Phase 3C --- I-20 Widening and Saluda River and CSX Bridge Replacements Design-Build Project
Project ID P043325 - Lexington County

2/11/2025 Open Forum

Date Posted: 2/24/2025

Non-Confidential Meeting Date: N/A

| | | | | | | | SCDOT | |
|--------------|----------|-----------|----------------|---|------------|----------|--|--|
| Question No. | Category | Section | Page / Doc No. | Question/Comment | Discipline | Response | Explanation | |
| 1 | PIP | Utilities | | <p>According to TP-140-2 Utility Report Appendix D Sheet U41, the water line along Riverchase Way is designated as both W1 and W2 which when compared to the utility owner key on the title sheet indicates both City of West Columbia and City of Columbia. Additionally, the note states "COC" to remain, however, within the preliminary utility report under City of Columbia's section there is no mention being located along Riverchase Way and it is only mentioned under City of West Columbia's section. It is our belief that this line is owned in its entirety by the City of West Columbia. This line could have impacts with the drainage improvements to the existing crosslines under Riverchase Way. With the City of Columbia relocations being performed in-contract and no mention how to handle any impacts to the City of West Columbia, please confirm this line is owned in its entirety by the City of West Columbia and any relocations would be handled post-award via contract change request.</p> | Utilities | Revision | <p>Updates to "CCR Phase 3C Utility Report Appendix" (PIP 140-2) and "Underground and Above Ground Utility Map" (TPA 140-5) will be provided in a future addendum prior to Cost Proposals to reflect ownership by the City of West Columbia for the waterline along Riverchase Way.</p> <p>As noted in TP Section 140.3 and the SCDOT Utility Accommodations Manual, potential conflicts should be avoided or minimized to the most practicable extent. Should Proposer's design have impacts to this waterline that would require relocation, this would be handled post-award through the contract change request process.</p> | |

