



- (✓) APPROVED
- ( ) APPROVED AS NOTED
- ( ) REVISE AND RESUBMIT
- ( ) NOT APPROVED

Approval is only for conformance with the design concept of the project and compliance with the information given in the Contract Documents. Contractor is responsible for dimensions to be confirmed and correlated at the job site; for information that pertains solely to the fabrication processes or to techniques of construction; and for coordination of the work of all trades.

DocuSigned by:  
Campco Engineering, Inc.

Robert L. Walski, P.E.

Reviewed By  
B3892A142482486...  
4/27/2020

Date



REV. DATE	REVISION	REV

ATS-SALES

CUSTOMER: CITY OF ROCK HILL

MAST ARM POLE DETAILS  
SC-161 &  
(SC-196) TWIN LAKES RD  
CITY OF ROCK HILL, SC

04/16/2020

16989-1

DESIGN BASED ON:  
AASHTO 6TH EDITION  
- 90 MPH  
- 25 YEAR RECURRENCE  
- FATIGUE CATEGORY II  
- NO GALLOPING LOADS  
- WORST CASE OF ACTUAL  
LOADS -VS- STANDARD  
LOADS